

GMA200-MW

Customer:

Order #:



Relay configuration

Date:

Relay	Designation (*1) (max. 20 characters)	Functionality (*2)	Mode of operation (*3)	Voting (*4)	Measuring points (*5)															
					01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16
01																				
02																				
03																				
04																				
05																				
06																				
07																				
08																				
09																				
10																				
11																				
12																				
13																				
14																				
15																				
16																				

About (*1) Designation: free text field for describing the relay function, e.g.:

Pre-alarm, main alarm, service, fault, external horn, internal horn, valve X, fan Y

About (*2) Functionality: describes the condition when relay switches, e.g.:

**AL1=Alarm1, AL2=Alarm2, AL3=Alarm3,
SRV-TRM=Maintenance transmitter, SRV-GMA=Maintenance GMA,
FLT-TRM=Fault transmitter, FLT-GMA=Fault GMA,
RESET=Horn acknowledgement during an active alarm**

About (*3) Mode of operation:

Mode of operation of the relay coil **open-circuit** or **closed-circuit**

About (*4) Voting:

OFF=no voting function; **2, 3, 4 of X** = At least 4 measuring points must meet the condition described under "Functionality" for switching.

About (*5) Measuring points:

X marks the measuring points which are relevant for the respective relay.